

29. TENDER ACCEPTANCE CONTRACT NO 2000/02-120 – SUPPLY OF WASTEWATER PUMPS FOR CHRISTCHURCH WASTEWATER TREATMENT PLANT TRICKLING FILTER PUMP STATION B

The Committee considered a report seeking approval to accept a tender to purchase the pumps required as part of the next stage of the Christchurch Wastewater Treatment Plant Upgrade. The tender required the provision of two pumps capable of pumping 1.5 cubic metres per second and tenders had been received from a total of three suppliers and were evaluated over a range of criteria, including operating costs, maintenance costs, speed bearing life, warranty and price.

The report recommended acceptance of the lowest tender which met all the required requirements and was within the budget amount of \$450,000.

The Committee **resolved** that the lowest tender from Pump Systems Ltd for two Everflow 700 P – 3 Stage Axial Flow Pumps be accepted for a total price of \$418,594.