

## 6. UPPER VALLEY ROAD STREAM PIPING AT 90A AND 100 DYERS PASS ROAD

The Committee considered a report from Bob Hopkins, which outlined the results of a detailed investigation of the catchment contributing to the waterway flowing past Mr J M Hamilton's property at 90A Dyers Pass Road, Mr Hamilton having made a submission to the annual plan regarding an increase in flow down the waterway experienced after new sumps were installed on Dyers Pass Road above his house.

The Committee **resolved** to approve the implementation of the following remedial measures:

- The piping of the valley floor from the downstream manhole outside 125 Hackthorne Road to north of Mr J M Hamilton's property (option 2 as outlined in the report, estimated to cost \$125,500).
- The obtaining of easements to prevent any further encroachment on the waterway and keep clear the secondary flow path.
- The renewal of the 300mm piping with 375mm piping after the piping of Mr Hamilton's property is installed.
- The improvement of the sump intakes near Westenra Terrace if the gullies they discharge into are found to be adequate.