

## 8. CORRECTION OF ERROR IN CHRISTCHURCH CITY DISTRICT PLAN

The Committee considered a report seeking approval to correct a minor error in the Christchurch City District Plan.

The Committee **resolved** that:

Pursuant to clause 16(2) of Schedule 1 to the Resource Management Act 1991, amend clause (x) of Appendix 10 in Part 6 of the Christchurch City District Plan to read:

*“(x) Stormwater disposal system, located along the site’s south-eastern boundary shall be designed to provide sufficient detention and attenuation so that flows from the proposed development **do not exceed 30 l/s** in all storm events up to and including a 50 year level of service. - - -”.*