

12. LOW WATER PRESSURE INVESTIGATION – HARAKEKE STREET

Officer responsible Water Services Manager	Author Bruce Bennett
Corporate Plan Output: Information and Advice - External	

The purpose of this report is to inform and update the Board on the steps taken by Council staff in monitoring the Council's mains supply in Harakeke Street during the summer months to see what effect the "draw off" has when peak demands put pressure on the overall system.

RESULTS

Mains pressure recordings were taken in July 1999 and March 2000. The pressure graphs were very similar for both summer and winter. They revealed no unacceptable pressure drops and compared favourably with Jeffreys Road Pumping Station records.

No complaints from this vicinity in respect to flow or pressure have been received by this office since the initial concerns from local residents were first raised and investigated.

Recommendation: That the report be received and the residents advised that the Council's reticulation in this area has been investigated showing that an adequate mains water supply is available in the vicinity of Harakeke Street.

Chairman's Recommendation: That the foregoing recommendation be adopted.